

ICON LEGEND

Throughout the catalog, you will notice different icons next to the product descriptions for our garments. The icons help you quickly determine new products, HRC protection, NFPA 2112/UL certification and fit charts.



NEW PRODUCT FOR 2012



FIT CHARTS

The number or letter used references specific fit charts located on pages 48-52.



HRC 1 PROTECTION

Arc-rated FR shirt and FR pants or FR coverall with a required minimum ATPV of 4.



HRC 2 PROTECTION

Arc-rated FR shirt and FR pants or FR coverall with a required minimum ATPV of 8.



HRC 3 PROTECTION

Arc-rated FR shirt and pants or FR coverall, and arc flash suit selected so that the system arc rating meets the required minimum and a required minimum ATPV of 25.



HRC 4 PROTECTION

Arc-rated FR shirt and pants or FR coverall, and arc flash suit selected so that the system arc rating meets the required minimum and a required minimum ATPV of 40.



NFPA 2112 / UL CLASSIFIED

Bulwark® Protective Apparel offers flame-resistant protective garments that are certified by Underwriters Laboratories to meet the requirements of NFPA® 2112 Standard on Flame Resistant Garments for Protection of Industrial Personnel Against Flash Fire, 2007 Edition.* NFPA 2113 Standard on Selection, Care, Use, and Maintenance of Flame Resistant Garments for Protection of Industrial Personnel Against Flash Fire, 2012 Edition, requires that garments cover the upper and lower body and flammable underlayers as completely as possible. Bulwark® garments meet this requirement either as a single garment such as a coverall or when worn with another certified garment such as a shirt or pants to provide both upper and lower body coverage.

**Bulwark® garments that are currently certified to NFPA 2112, 2007 Edition will undergo recertification to the 2012 Edition prior to August 2012.*



ELECTRICAL SAFETY NFPA® 70E HRC CHART





HAZARD/RISK CATEGORY	CLOTHING DESCRIPTION	REQUIRED MINIMUM Arc Rating of PPE cal/cm ²
	Arc-rated FR shirt and FR pants or FR coverall	4
	Arc-rated FR shirt and FR pants or FR coverall	8
	Arc-rated FR shirt and pants or FR coverall, and arc flash suit selected so that the system arc rating meets the required minimum	25
	Arc-rated FR shirt and pants or FR coverall, and arc flash suit selected so that the system arc rating meets the required minimum	40

Table 130.7 (C) (II)